

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:39 pm

PWS ID: UTAH22072 **Name:** ECHO RESORT
Legal Contact: ECHO RESORT **Rating:** Approved
JOYE RAY **Rating Date:** 04/09/1996
Address: PO BOX 746 **Activity Status:** Active
COALVILLE, UT 84017
Phone Number: 435-336-9894
City Served (Area):
County: SUMMIT COUNTY

System Type: Non-community **Last Inv Update:** 04/16/2009 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 07/17/2007 **Total Dsgn Cap:**
Population: 900 **Surveyor:** JOHN H OAKESON **Total Emerg Cap:**
Oper Period: 5/1 to 9/30

Gal/Day Gal/Min

Contacts

| Contact Type | Name | Title | Phone Numbers | Emergency | Email Address |
|--------------|-----------|-------|---------------|-----------|---------------|
| AC | RAY, JOYE | | 435-336-9894 | | |

Service Connections

| Connection Type | Meter Type Code | Meter Size | Number Connections |
|-----------------|-----------------|------------|--------------------------|
| Combined | Unmetered | 0 | 43 |
| | | | 43 Total Svc Connections |

Storage

Total Storage: 300 GAL **Number of Units:** 1 **Adequate Capacity:** YES

| No. | Name | Type | Effective Volume | Constr Matl | Overflow Elev | Activity Status | Press'd |
|-------|------------------------|-------------|------------------|-------------|---------------|-----------------|---------|
| ST001 | STORAGE FACILITY ST001 | Hydropneuma | 300 GAL | Steel | | A | NO |

Distribution System

| Pump Type | Total Dyn Head ft H2O P.S.I. | Pressure Adequate | Cross Connection | Auhority Statement |
|-----------|-----------------------------------|-------------------|------------------|--------------------|
| No | | | | |

Sources

| No. | Source Name | Activity Status | Source Type | Well Dia. | Safe Yield * | Pump Capacity | Location Data On File | Water Type | Availability | Period of Operation | Grnd Wtr Indicator |
|-------|------------------|-----------------|-------------|-----------|--------------|---------------|-----------------------|------------|--------------|---------------------|--------------------|
| WS001 | ECHO RESORT WELL | Active | WL | 8 | 40 GPM | 40 GPM | Yes | GW | Seasonal | 5/1 to 9/30 | |

**Reports measured flow for wells, approved design capacity for all other sources.*